

CITY OF GAITHERSBURG

REQUIREMENTS FOR THE SUBMITTAL OF SPRINKLER AND STANDPIPE PLANS (NFPA 13, 13D, 13R, AND 14 SYSTEMS)

Effective: April 2021

Page 1 of 11

A. PERMIT PROCEDURES

1. Permits and submittals are required for all work involving any sprinkler additions or modifications, except limited area systems of 5 or fewer sprinklers or those meeting **ALL** of the following criteria:
 - a. Non-residential, **and**
 - b. 10 sprinklers or less being added or modified, **and**
 - c. No increase in hazard classification or building footprint.
2. ALL sprinkler work must be performed by a contractor with a valid Maryland Sprinkler Contractor License, regardless of whether or not a permit is required. If no permit is required, a completed ***Contractor's Material & Test Certificate for Aboveground Piping*** must be provided to the inspector at time of construction inspection. **When a permit is required, work on the system shall not begin until the permit is obtained, and the City-approved plans and Fire Protection Permit are on the job site.**
3. A FIRE SPRINKLER/STANDPIPE PERMIT APPLICATION form must be completed in full and included with all initial submittals. **Application must include contact persons and email addresses in all locations on the application where indicated.** (The Application form can be downloaded from the city website, search keyword "Fire Protection Permits".)
4. Application fee(s) must be paid at the time application is made. (See City website for schedule of fees, and see Permits & Inspections page for instructions on submitting applications for permits.)
5. For continuations of large projects, or revisions to a current permit, include a *copy* of the original permit, marked up to indicate it is a revision to that permit.
6. Once the review has been completed, the applicant will be contacted with the result of the review as follows:
 - a. Approved plans with the comments, or
 - b. At the discretion of the reviewer, the submittal may be suspended or disapproved, and a correction list will be emailed to the applicant, who is then responsible for submitting revisions/corrections in a timely manner.

B. GENERAL SUBMITTAL REQUIREMENTS

1. Permit documents must be submitted in PDF format via email to Plancode@gaitHERSBURGMD.GOV.
2. Application for sprinkler permit does ***not*** have to wait until issuance of the building permit, and a copy of the building permit is ***not*** required to be included with the application for sprinkler permit.
3. **DO NOT submit manufacturer's specifications (cut sheets).** Instead, ensure that all manufacturers' information (i.e. make, model numbers, etc.) has been incorporated into the plans so that, if need be, the information with respect to materials, products and their listings can be verified via the manufacturer's website or UL's website.

REQUIREMENTS FOR THE SUBMITTAL OF SPRINKLER AND STANDPIPE PLANS (NFPA 13, 13D, 13R, AND 14 SYSTEMS)

Page 2 of 11

B. GENERAL SUBMITTAL REQUIREMENTS (cont'd.)

4. For modifications or additions to existing systems, the plans must show enough of the existing system to enable complete review and to verify existing system layout and compatibility of all equipment. (In many cases, this will require the plan to show sprinklers and piping outside of the work area.)
5. Submittals for new commercial sprinkler systems must include a completed *Owner's Certificate*.
6. For submittals involving work on a portion of any plan (such as tenant work or partial revisions), the area of work must be clearly defined. Any areas shown that are not within the scope of work must be crossed off or otherwise clearly delineated as not within the scope of work.
7. For complexes, (such as garden apartments or townhouses) where typical buildings prevail, the initial submittal can prove the design for all locations. The plans will need to show the typical arrangements and provide verification that the most hydraulically remote building (highest and most remote from water source) has been calculated. Future permits in that same development can be then be submitted based on the original design (with reference to the original permit number), and will be in the Fast Track review queue.

C. INFORMATION REQUIRED ON DRAWINGS

1. General

- a. Project name and address(es). (Include all addresses if scope of work covers multiple addresses.)
- b. Project owner's name and address, including zip code.
- c. Building construction permit number. (If work is part of a construction project.)
- d. Maryland State Fire Sprinkler Contractor License # & expiration date. **(required by state law)**
- e. Each page must include the designer's name and **original signature or certified electronic signature**, certification number, and expiration date. **(required by state law)**
- f. Sprinkler contractor name, address, **telephone number, & sprinkler contractor contact person.**
- g. Symbol & abbreviation key.
- h. Minimum scale for floor plans is 1/8" per ft. (For residential, 1/4" per ft. is preferred.)
- i. Applicable NFPA standard(s) and edition(s) used.
- j. For submittals with calculations or new pipe schedule systems, plans must indicate the WSSC Low Hydraulic Gradient (LHG) and High Hydraulic Gradient (HHG), or Hydraulic Information Sheet data.

2. Architectural

- a. Overall use (i.e. office building, warehouse, townhouse, day care, etc.) – both IBC and NFPA use group/occupancy classifications.
- b. Occupancy (specific intended use) of all rooms and areas.
 - If the Classification of Occupancy (hazard) is not obvious by the room name, provide further clarification.
 - For laboratories, provide NFPA 45 Laboratory Unit Fire Hazard Classification.
- c. Locations of all partitions and doors.
- d. Ratings of any fire walls, partitions, and doors; in particular when using the room design method.
- e. Ceiling construction and height.
- f. Show all ceiling obstructions (lights, bulkheads, etc.), ceiling pockets, and their dimensions.

REQUIREMENTS FOR THE SUBMITTAL OF SPRINKLER AND STANDPIPE PLANS (NFPA 13, 13D, 13R, AND 14 SYSTEMS)

Page 3 of 11

C. INFORMATION REQUIRED ON DRAWINGS (cont'd.)

2. Architectural (cont'd.)

- g. Explain blind spaces and other areas where sprinklers are not installed.
- h. Full height cross sections in adequate locations and with enough detail to depict all conditions. Provide elevations in terms of sea level for all floors and dimensions from the lowest floor.
- i. In garages with standpipes, show parking space layout to enable verification of travel distance / hose reach. (hose reach requirement cannot be measured through parking spaces)
- j. Show water curtains & 18-inch deep draft stops when required around floor openings.

3. Site Plan

- a. To scale (indicate the scale) or dimensioned.
- b. Size, type, and arrangement of underground water mains and sprinkler supply line.
- c. Test point, water supply, and WSSC Low & High Hydraulic Gradient information.
- d. Sea level elevations for supply point & building slab.
- e. If underground pipe is installed by sprinkler contractor, show depth of cover.
- f. Point of compass. (North arrow)
- g. Fire Department Connection. (Within 100' of a hydrant for NFPA 13 & 14 systems.)
- h. Flow tests: show gauge & flow hydrants.
- i. When the Site Plan contains multiple buildings, it must clearly indicate the building(s) for which application for permit is being made and the address number of each building.

4. Water supply information

- a. New Tap – All systems **except** NFPA 13D:
 - Obtain information from WSSC Hydraulic Information Sheet (HIS) from general contractor, consulting engineer, civil engineer or building owner.
 - Submit copy and/or reproduce on drawings.
- b. New Tap if no HIS exists – all systems **except** NFPA 13D:
(Note: This is usually only applicable for very small buildings or NFPA 13R systems.)
 - Obtain a current [fire flow test report](#) from WSSC Development Services, 14501 Sweitzer Lane, Laurel, MD, 20707. (301-206-4258) www.wsscwater.com
- c. Existing underground lines – **all systems**:
 - Flow test performed inside the building shall be used due to unknown condition and available supply of the underground pipe. (Contact the City of Gaithersburg at 301-258-6330 to schedule a Fire Inspector to witness this test.)
 - Flow test must be no older than 1 year. (Remember to adjust for Low Hydraulic Gradient as above, and that outside hose allowance must still be included.)
- d. New tap - NFPA **13D** systems **only**:
 - Obtain [Low and High Hydraulic Gradient information](#) from WSSC Permit Services Unit INTAKE (301-206-8650).
 - Convert to pressure available by subtracting the highest building elevation and multiplying by 0.433 as follows: (Low Gradient – building slab elevation) x 0.433 psi/ft. = pressure available at slab

REQUIREMENTS FOR THE SUBMITTAL OF SPRINKLER AND STANDPIPE PLANS (NFPA 13, 13D, 13R, AND 14 SYSTEMS)

Page 4 of 11

C. INFORMATION REQUIRED ON DRAWINGS (cont'd.)

4. Water supply information (cont'd.)

e. Pipe schedule systems:

- Provide a graph of water supply vs. system demand to verify compliance with NFPA 13 water demand requirements for pipe schedule systems.
- Correct the water supply data to the base of the system riser.
- Show the end sprinkler pressure, elevation loss, and backflow preventer loss.

f. Fire pumps:

- Provide pump make and model number, and pump performance curves.
- Indicate the pump piping arrangement.

g. Water tanks:

- Indicate the tank capacity.
- Provide details of the tank piping and arrangement.

5. System Layout

- a. Pipe sizes (typical branch line sizes are acceptable).
- b. Dimensions between sprinklers, and dimensions from sprinklers to walls in all areas & rooms, and center-to-center dimensions or cut-lengths of pipe. (**ceiling grid \neq dimensions**)
 - For sloped ceilings, provide dimensions both along the slope and horizontal dimensions.
 - For above and below ceiling systems, give dimensions for both.
- c. Sizes & lengths of riser nipples & drops.
- d. Locations of high temperature sprinklers, if any.
- e. Pipe sizing shall be by pipe schedules or as proven by hydraulic calculation.
- f. Hanger locations.
- g. Valves, drains, and test connections.
- h. Hydraulic reference points corresponding to calculations.
- i. For residential sprinklers, indicate danger areas near heat producing devices in accordance with manufacturer's recommendations (cross-hatch & show *on the plans*, not just in a chart).
- j. For additions or modifications to existing systems, show enough of the existing system to enable verification of pipe schedule, feed mains, cross mains, & supply points.
- k. Elevations of sprinklers & supply points.
- l. Alarms and/or alarm connections.
- m. Sprinkler control valves (except elevator control valves) must be in stairs, valve rooms, or pump rooms.
- n. Multiple fire department connections on the same building must be interconnected.

REQUIREMENTS FOR THE SUBMITTAL OF SPRINKLER AND STANDPIPE PLANS (NFPA 13, 13D, 13R, AND 14 SYSTEMS)

Page 5 of 11

C. INFORMATION REQUIRED ON DRAWINGS (cont'd.)

5. System Layout (cont'd.)

o. Fire department connection(s):

- Show check valve & ball drip.
- Provide multiple Fire Department Connections for all high rises, and preferably wherever more than two inlets are required.
- Per City Fire Code, the number of inlets shall be as follows:

<u>System Demand (gpm)</u>	<u>Min. # of 2½" inlets</u>
Up to 749	2
750 to 999	3
1000 and above	4

p. Zoning:

- By floor when required by City of Gaithersburg Fire Code.
- Coordinate with fire alarm & smoke control zones. Atriums will usually require independent zones.
- For 2-story floor openings that are not classified as atriums and that are enclosed on the upper level, sprinklers at the top of the opening must be zoned with the lower level.

6. Riser Diagram

- a. Sizes of pipe and all devices.
- b. Make, model & size of alarm, dry pipe, and/or preaction valves.
- c. Fire department connection.
- d. Make, model & size of backflow preventer, detector check, and water meter (if required).
- e. Means for full flow testing of the backflow preventer. (where required)
- f. Air supervision for dry sprinkler systems or manual dry standpipe systems.
- g. For residential sprinkler systems serving a single dwelling unit, indicate the location of the drain valve and combined domestic/sprinkler control valve.

7. Sprinkler Calculation Design Areas (except NFPA 13D & 13R)

- a. Show clearly the boundary of each design area. It shall comprise the actual floor area covered inside walls and halfway between adjacent sprinklers. **Indicate *actual* total area calculated** not the minimum required by NFPA 13.
- b. For the room design method or irregular areas not meeting the $1.2 \sqrt{A}$ requirement, show fire resistance ratings of walls and doors to conform to NFPA 13.

8. Notes

- a. A Sprinkler Legend must be provided on each sprinkler plan sheet showing all sprinkler symbols used on that sheet. Legend must include make, model, orifice size, K-Factor, temperature rating, S.I.N., and number of sprinklers for each sprinkler symbol/type.
- b. Capacity (in gallons) of each dry pipe system.
- c. Pipe type & fitting types, welds and bends. If it varies, give type for each size.
- d. If non-metallic pipe is used:
 - Indicate hanger intervals per manufacturer.
 - Show detail of method of restraint at sprinkler to counteract water force.

REQUIREMENTS FOR THE SUBMITTAL OF SPRINKLER AND STANDPIPE PLANS (NFPA 13, 13D, 13R, AND 14 SYSTEMS)

Page 6 of 11

C. INFORMATION REQUIRED ON DRAWINGS (cont'd.)

8. Notes (cont'd.)

- e. System design criteria (for each zone and/or calculated area).
 - If pipe schedule: Indicate Classification of Occupancy (hazard) in accordance with Chapter 5 of NFPA 13.
 - If calculated: Indicate Classification of Occupancy (hazard), density, design area (*actual* area calculated, *not* the minimum area required by NFPA 13), hose allowance, safety factor, sprinkler protection area of coverage, **and calculated pipe schedule**.
 - If storage: Provide design analysis referencing figures, curves, and area/density modifications.

9. Standpipe Systems

- a. Class I only. (Class II and Class III systems are prohibited.)
- b. Riser & hose connection locations and riser detail, including gauges at the top of each riser.
- c. Hose connection locations must meet required travel distance (hose reach). Show all doors to verify compliance. Travel distance/hose reach in open areas must be measured at right angles.
- d. If supplemental hose connections are needed outside of stair enclosures in order to meet travel distance/hose reach requirements, the supplemental hose connections must be located in public or main corridors as consistently as possible on all floor levels. Hose connections located outside of stairs cannot substitute for those required inside stair enclosures.
- e. Show the height of the hose connection above the finished floor.
- f. Pressure regulating valves (PRVs) are not permitted if it is possible to obtain the required pressures with the main pump relief valve. If this is not possible, show PRVs only on hose connections that could have pressures above 175 psi. Indicate the highest potential pressure at each hose connection, and indicate pressure setting of each PRV.
- g. Hose connections located outside of stairs in Parking Garages shall not be obstructed by parking and shall be labeled with prominent signs or red column stripes. Additionally, in accordance with City Fire Code, supplemental hose connections shall be located adjacent to drive aisles with acceptable barriers, or they shall be accessible via minimum 44" wide walkways defined by curbs or other approved fixed barriers.

10. Fire Pump Details (if Fire Pump is part of the scope of work)

- a. Capacity (flow & pressure), make, model, listing.
- b. Cross section.
- c. Bypass.
- d. Jockey pump.
- e. Controller locations.
- f. Relief valve, if required for diesel pumps or excess pressure due to the high gradient and 140% of the rated churn pressure.
- g. Relief valve drain piped outside.
- h. Existing pumps not in conformance must be upgraded if adding or extending systems.
- i. The eccentric suction reducer must be installed with the flat side on the bottom if the fed directly with an elbow from above.
- j. Hydrostatic test pressure: If the system can experience pressures greater than 150 psi due to the High Gradient plus 140% of the rated pressure, disregarding the relief valve setting.

REQUIREMENTS FOR THE SUBMITTAL OF SPRINKLER AND STANDPIPE PLANS (NFPA 13, 13D, 13R, AND 14 SYSTEMS)

Page 7 of 11

C. INFORMATION REQUIRED ON DRAWINGS (cont'd.)

11. High Piled & High Rack Storage

- a. Storage height and arrangement including aisle widths.
- b. Commodity classification.
- c. Owner's written certification of all storage limitations imposed by the sprinkler design.
- d. Small hose connections. (Occupant use hose is prohibited in new & existing buildings.)
- e. Multiple level storage with open grated walkways must be designed for two scenarios:
 - The entire storage height as if the walkways were unobstructed, **and**
 - Each level individually as if the walkways were obstructed.

12. Speculative Spaces (subject to tenant changes regardless of lease term)

- a. New speculative spaces shall be designed per City of Gaithersburg Fire Code for adequate system flexibility.
- b. "Mains only" may be installed in future tenant spaces with no storage. Shell approval must include protection for all core and non-leasable areas, including means of egress.
- c. Provide phantom calculations to verify pipe sizing and sprinkler protection area of coverage for future tenant work for "mains only" installations, or for phased retrofits.
- d. For high piled or rack storage designs, hose connections, rack sprinklers, and column sprinklers may be installed as needed for each tenant. However, hose connection supply points must be shown for calculation purposes.
- e. Tenant protection area of coverage per sprinkler and pipe sizing changes shall conform to shell calculations and shall be consistent on any given floor.
- f. A change to a lower degree of Classification of Occupancy (hazard) must use the same pipe sizing as the shell layout, and spacing may be increased by density conversion. For example, a system originally designed to Ordinary Hazard (Group 2) with a density of 0.20 gpm/ft² and sprinkler spacing of 100 ft² per sprinkler would have a minimum sprinkler flow of 20 gpm. The new spacing for Light Hazard would be 20 gpm/0.10 gpm/ft², which equals 200 ft² per sprinkler.
- g. A change to a higher degree of Classification of Occupancy (hazard) must be recalculated, unless the area changed consists of small rooms using the same pipe sizing and a decrease in spacing by density conversion. For example, a system originally designed to Light Hazard with a density of 0.10 gpm/ft² and sprinkler spacing of 168 ft² per sprinkler would have a minimum sprinkler flow of 16.8 gpm. The new spacing for Ordinary Hazard (Group 2) would be 16.8 gpm/0.20 gpm/ft², which equals 112 ft². In order to use this conversion method, these small rooms shall not have more than 6 sprinklers if the original design area was at least 1,500 ft², or no more than 3 sprinklers if the design area was less than 1,500 ft².
- h. The room design method and small room calculation exceptions are not permitted in speculative spaces due to potential for future wall demolition.
- i. Minimum 1" outlets shall be provided.
- j. Plugged outlets must be considered sprinklers for the purpose of pipe sizing.

REQUIREMENTS FOR THE SUBMITTAL OF SPRINKLER AND STANDPIPE PLANS (NFPA 13, 13D, 13R, AND 14 SYSTEMS)

Page 8 of 11

C. INFORMATION REQUIRED ON DRAWINGS (cont'd.)

13. Tenant Plans

- a. Tenant location or area of work must be highlighted, and all areas outside the scope of work crossed off or otherwise clearly indicated as such.
- b. Provide all applicable notes from the list on Page 11 of this document.
- c. If the original system design criteria are not available, recalculation will be required.
- d. Original system criteria must be adhered to throughout any given floor. Redesign must be on an entire floor basis.
- e. Show enough of adjacent areas to enable verification of pipe sizing, and sprinkler spacing along both sides of any new walls.
- f. Provide arm-over and tie-in details.
- g. Plan must indicate the number of added and relocated sprinklers. Cutting or extending drops is not considered a relocate if sprinkler locations are not changed and the sprinkler K-factor is unchanged.
- h. If standpipes are provided, show hose connections and all doors to enable verification of compliance with travel distance (hose reach) limitations in accordance with NFPA 14.
- i. Locate new standpipe hose connections per Section 9 above.

D. INFORMATION REQUIRED ON CALCULATIONS

1. General

- a. Calculations shall provide all information as required by the applicable NFPA standard.
- b. Submit as many calculations as necessary to prove all conditions, including largest protection area of coverage per sprinkler, smallest pipe sizing, most demanding piping arrangements, most demanding sprinkler types, and different pipe types.

2. Cover sheet of each calculation

- a. Date.
- b. Project name and address.
- c. Floor level.
- d. Description of area/location on the floor.
- e. Identification corresponding to design area on plan.

3. Design Criteria for NFPA 13D Systems

- a. Two sprinklers flowing at the required flow and pressure.
- b. Three sprinklers flowing if required by listing or City of Gaithersburg Fire Marshal.

REQUIREMENTS FOR THE SUBMITTAL OF SPRINKLER AND STANDPIPE PLANS (NFPA 13, 13D, 13R, AND 14 SYSTEMS)

Page 9 of 11

D. INFORMATION REQUIRED ON CALCULATIONS (cont'd.)

4. Design Criteria for NFPA 13R systems

- a. All sprinklers within a compartment, up to a maximum of four sprinklers under a smooth, flat ceiling, or five sprinklers where required by City of Gaithersburg Fire Marshal.
- b. Sprinklers calculated must be the hydraulically most demanding.
- c. Areas outside dwelling units must be calculated per NFPA 13 unless the area meets all the criteria in NFPA 13R for a four-sprinkler design.
- d. Garages must be calculated in accordance with NFPA 13R.

5. Design Criteria for all other systems

- a. Classification of Occupancy. (Hazard)
- b. Design area. (**Actual area calculated**, not the minimum required by NFPA 13.)
- c. Design density.
- d. Inside and outside hose allowances.
- e. Protection area of coverage per sprinkler as calculated.
- f. Water supply and pump information.
- g. Any general storage, shipping, receiving, loading, or other storage areas, regardless of room name, are classified as Ordinary Hazard (Group 2), unless special usage conditions and written owner certification allow Ordinary Hazard (Group 1) per NFPA 13 table for miscellaneous storage.
- h. Multi-purpose rooms in schools and other occupancies are considered at least Ordinary Hazard (Group 1). If there is no multi-purpose room in a school, the gymnasium shall be designed as Ordinary Hazard (Group 1).
- i. Space-saving filing or storage units that close/collapse against one another are classified as Extra Hazard (Group 2) due to the shielding of combustibles, unless it is demonstrated that they comply with the special design criteria in NFPA 13.
- j. Laboratory sprinkler systems, including those in health care occupancies, must be designed in accordance with NFPA 45 classifications.

6. Calculation Format for NFPA 13D systems

- a. Per NFPA 13D.
- b. Include friction losses for any devices such as backflow prevention devices and meters.
- c. Water pressure at street per Section C.4.a above.
- d. If system covers more than one dwelling unit, include 5 gpm per unit domestic demand.
- e. Match the source elevation in the calculations to the Low Hydraulic Gradient adjustment point.

7. Calculation Format for all other systems

- a. Per NFPA 13 or NFPA 13R, as applicable.
- b. Sprinkler K-factor(s) and Sprinkler Identification Number(s) (SINs).
- c. Hydraulic reference points.
- d. Pipe sizes & lengths.
- e. Equivalent lengths for all fittings & devices – include & label.
- f. Friction loss factors expressed in psi/foot.
- g. Total friction loss between reference points.
- h. Pressure at each reference point.

REQUIREMENTS FOR THE SUBMITTAL OF SPRINKLER AND STANDPIPE PLANS (NFPA 13, 13D, 13R, AND 14 SYSTEMS)

Page 10 of 11

D. INFORMATION REQUIRED ON CALCULATIONS (cont'd.)

7. Calculation Format for all other systems (cont'd.)

- i. Velocity & normal pressures (if used).
- j. Add inside hose allowance at the nearest hose connection and outside hose allowance at the nearest fire hydrant. (NFPA 13 systems only)
- k. Include water curtain demand for floor openings with the nearest calculation on the same floor. (NFPA 13 systems only)
- l. Include drops & armovers in calculations.
- m. Continue calculations to:
 - The point of connection when using the HIS.
 - The gauge hydrant when using an outside flow test.
 - The gauge location when using an inside flow test.

8. Other

- a. Summary graph sheet showing the adjusted water supply, pump adjustment, hose allowance, and system demand point.
- b. Gridded systems must include peaking proof and grid sketches showing reference points, flows, and flow directions.
- c. For systems with fire pumps, supply and demands must be corrected to the location of the pump to verify adequate suction pressure at 150% of pump capacity at Low Hydraulic Gradient.
- d. For systems with fire pumps, a maximum of 101% of the pump's rated pressure shall be used for churn unless a certified curve shows a higher churn pressure.
- e. For standpipe systems, include both the fire pump and FDC calculations unless the pump is designed for the full demand.
- f. Standpipe calculations may only use multiple FDC's for supply points if each meets the position and location requirements, including the proximity to the nearest fire hydrant.
- g. If pumps and/or tanks are used in areas with a public water supply, submit calculations to prove that the system cannot be designed to work with the public supply. All design variations, including sprinkler protection area of coverage, sprinkler orifice, pipe sizing, looping, and gridding must be explored before the pumps and/or tanks will be allowed.

REQUIREMENTS FOR THE SUBMITTAL OF SPRINKLER AND STANDPIPE PLANS (NFPA 13, 13D, 13R, AND 14 SYSTEMS)

Page 11 of 11

- TENANT SPRINKLER DRAWING NOTES -

All applicable notes must be included on the plans

Original Design Information:

Hazard: _____ Calculated Area: _____ ft² Density: _____ gpm/ft²
Maximum sprinkler protection area of coverage: _____ ft² Safety Factor: _____ psi
Sprinkler make/model: _____ Orifice: _____ Temp: _____ °F SIN: _____
Pipe Types: _____ Fitting types _____
Calculated Pipe Sizing: Armover diameter: _____ Length: _____'-_____"
_____ sprinklers on _____-inch pipe
_____ sprinklers on _____-inch pipe
_____ sprinklers on _____-inch pipe

Hazard Change:

- Density conversion to higher hazard: (_____ gpm orig. flow)/(_____ gpm/ft² new density) = _____ ft²
(Only allowed for areas with 6 or fewer sprinklers for an original design area of at least 1,500 ft², or 3 or fewer sprinklers for an original design area less than 1,500 ft²)
New spacing to be used in all rooms of _____ Hazard (Group _____)

- Density conversion to lower hazard: (_____ gpm orig. flow)/(_____ gpm/ft² new density) = _____ ft²
New spacing to be used in all rooms of _____ Hazard (Group _____)

New Sprinklers:

Make/model: _____ Orifice: _____ K-factor: _____ Temp: _____ °F SIN: _____

of New Sprinklers: _____ # of Relocated Sprinklers (off original outlets): _____

New Pipe: Detail # _____ for armover/tie-in details

Hangers to be installed per NFPA 13, see detail # _____

Hydrostatic test pressure shall be _____ psi due to high gradient + pump churn (w/o relief valve)

Tenant Details:

Unless noted otherwise, all rooms are _____ occupancy, and ceiling height is _____

Laboratories are NFPA 45 Hazard Classification _____ (A, B, C, or D)

Tenant owner's full address: _____

Contact Person: _____ Phone: _____

City Building Construction Permit number: _____

MD state sprinkler license: Number	Expiration date
1	1/1/2025
2	1/1/2025
3	1/1/2025
4	1/1/2025
5	1/1/2025
6	1/1/2025
7	1/1/2025
8	1/1/2025
9	1/1/2025
10	1/1/2025
11	1/1/2025
12	1/1/2025
13	1/1/2025
14	1/1/2025
15	1/1/2025
16	1/1/2025
17	1/1/2025
18	1/1/2025
19	1/1/2025
20	1/1/2025
21	1/1/2025
22	1/1/2025
23	1/1/2025
24	1/1/2025
25	1/1/2025
26	1/1/2025
27	1/1/2025
28	1/1/2025
29	1/1/2025
30	1/1/2025
31	1/1/2025
32	1/1/2025
33	1/1/2025
34	1/1/2025
35	1/1/2025
36	1/1/2025
37	1/1/2025
38	1/1/2025
39	1/1/2025
40	1/1/2025
41	1/1/2025
42	1/1/2025
43	1/1/2025
44	1/1/2025
45	1/1/2025
46	1/1/2025
47	1/1/2025
48	1/1/2025
49	1/1/2025
50	1/1/2025
51	1/1/2025
52	1/1/2025
53	1/1/2025
54	1/1/2025
55	1/1/2025
56	1/1/2025
57	1/1/2025
58	1/1/2025
59	1/1/2025
60	1/1/2025
61	1/1/2025
62	1/1/2025
63	1/1/2025
64	1/1/2025
65	1/1/2025
66	1/1/2025
67	1/1/2025
68	1/1/2025
69	1/1/2025
70	1/1/2025
71	1/1/2025
72	1/1/2025
73	1/1/2025
74	1/1/2025
75	1/1/2025
76	1/1/2025
77	1/1/2025
78	1/1/2025
79	1/1/2025
80	1/1/2025
81	1/1/2025
82	1/1/2025
83	1/1/2025
84	1/1/2025
85	1/1/2025
86	1/1/2025
87	1/1/2025
88	1/1/2025
89	1/1/2025
90	1/1/2025
91	1/1/2025
92	1/1/2025
93	1/1/2025
94	1/1/2025
95	1/1/2025
96	1/1/2025
97	1/1/2025
98	1/1/2025
99	1/1/2025
100	1/1/2025

Standpipe: Code (check one): ☐ Before 4/11/95 (100' hose with 30' stream)
☐ After 4/11/95 sprinklered (200' hose)
☐ After 4/11/95 not fully sprinklered (150' hose)
 Number of new fire hose connections: (5' AFF, with caps and chains)